

2. Supplement

(Supplement according to EC-Directive 94/9 Annex III letter 6)

ZELM ex

to EC-type-examination Certificate

ZELM 03 ATEX 0198 X

Equipment: **Centrifugal fan type RVK 315Y4**
Manufacturer: **Systemair GmbH**
Address: **Seehöfer Str. 45, D-97944 Windischbuch**

Description of supplement

This Supplement concerns the alteration of the type designation of the centrifugal fan. The type designation of the centrifugal fan is in future:

RVK-EX 315D4

Moreover the documentation was adapted and the compliance of the equipment to the EN 60079-0:2009 was checked.

The marking, the electrical and all other data as well as the "Special conditions for safe use" according to the EC-type-examination Certificate ZELM 03 ATEX 0198 X inclusive the 1. and 2. Supplement remain unchanged and are valid further on.

The centrifugal fan shall only be manufactured in future according to this 2. Supplement.

Report No.

ZELM Ex 02214131040

Essential Health and Safety Requirements

The essential health and safety requirements are still fulfilled by compliance with the following Standards:

EN 13463-1:2009
EN 60079-0:2009

EN 13463-5:2011
EN 60079-7:2007

EN 14986:2007

Braunschweig, 2014-06-12

ZELM ex

**Zertifizierungs-
stelle**



Zertifizierungsstelle ZELM ex
Dipl.-Ing. Harald Zelm

**ZELM
ex**

Sheet 1 of 1

EC-type-examination Certificates without signature and stamp are not valid. This EC-type-examination Certificate may only be circulated without alteration. Extracts or alterations are subject to approval by the Prüf- und Zertifizierungsstelle ZELM ex. This English version is based on the German text. In the case of dispute, the German text shall prevail.

ZELM ex
Prüf- und Zertifizierungsstelle
Siekgraben 56 · D-38124 Braunschweig