



Notified body N° 0370



CERTIFICATE

Nr.

0370-CPR-0923

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. PART 3. SPECIFICATION FOR POWERED SMOKE AND HEAT EXHAUST VENTILATORS: PRODUCT RANGE HGHT V/H F300₆₀

Produced by:

SOLER Y PALAU SISTEMAS DE VENTILACIÓN, S.L.U.
C/ LLEVANT, 4
08150 PARETS DEL VALLÈS (BARCELONA)

And produced in the manufacturing plant:

SOLER Y PALAU INDUSTRIES, S.L.U.
CTRA. PUIGCERDA, KM. 108
17500 RIPOLL (GIRONA)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 12101-3:2002, EN 12101-3:2002/AC:2005

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 3rd December 2010 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed and modified on 7th February 2014.

Bellaterra, 7th February 2014

LGAi Technological Center, S.A. LGAi Technological Center, S.A.
Jordi Brufau Redondo
General Manager

Xavier Ruiz Peña
Product Conformity B.U., Managing Director



This document is not valid without its technical annex, whose number coincides with the number of certificate.

TECHNICAL ANNEX

0370-CPR-0923

CERTIFICATE OF CONSTANCY OF PERFORMANCE

PRODUCT

- Extractor tested inside of the furnace an fan's tested upstream airflow
- Extractor F₃₀₀ - 60 min
- Dual use
- Tested at 50 Hz 400 V
- Extractors tested with motor Weg F300. (Smoke Extraction Motor-TEFC V2 by WEG)
- Kind of snow: SL 1000 (only model V)
- Wind charge (only model H)
- The complete technical data of the certified range are detailed in the technical file and the range report nº 10/100522-63 M1.

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Response delay	6.4 & 6.5.2.	NA
Operational reliability	6.7	NA
Effectiveness of smoke/hot gas extraction Performance parameters under fire conditions	6.1, 6.2, 6.3 & 6.8	F300(60)
Resistance to fire: - Smoke leakage - Mechanical stability	6.1.2	PASS
Ability to open under environmental conditions	6.4	NA
	6.5.1	SL0
	6.6	NA

PASS; NPD = No Performance Determined; NA = Not Applicable

TECHNICAL ANNEX

0370-CPR-0923

Summary list of fire-resistant axial extractors: HGHT H/V:

HGHT RANGE 4 Poles					
Model	Power (kW)	Motor size	Model	Power (kW)	Motor size
4-800/3	1,1	90S	4-900/3	2,2	100L
	1,5	90L		3	100L
	2,2	100L		4	112M
	3	100L		5,5	132S
	4	112M		7,5	132M
4-800/6	5,5	132S	4-900/6	3	100L
	1,5	90L		4	112M
	2,2	100L		5,5	132S
	3	100L		7,5	132M
	4	112M		9,2	132M
	5,5	132S		11	160M
4-800/9	7,5	132M	4-900/9	15	160L
	2,2	100L		4	112M
	3	100L		5,5	132S
	4	112M		7,5	132M
	5,5	132S		9,2	132M
	7,5	132M		11	160M
4-800/12	9,2	132M	4-900/12	15	160L
	11	160M		18,5	180M
	2,2	100L		4	112M
	3	100L		5,5	132S
	4	112M		7,5	132M
	5,5	132S		9,2	132M
	7,5	132M		11	160M
	9,2	132M		15	160L
	11	160M		18,5	180M

TECHNICAL ANNEX 0370-CPR-0923

HGHT RANGE 4 Poles					
Model	Power (kW)	Motor size	Model	Power (kW)	Motor size
4-1000/3	3	100L	4-1250/3	7,5	132M
	4	112M		9,2	132M
	5,5	132S		11	160M
	7,5	132M		15	160L
	9,2	132M		18,5	180M
	11	160M		22	180L
	15	160L		30	200M
4-1000/6	4	112M	4-1250/6	37	225S/M
	5,5	132S		11	160M
	7,5	132M		15	160L
	9,2	132M		18,5	180M
	11	160M		22	180L
	15	160L		30	200M
	18,5	180M		37	225S/M
4-1000/9	22	180L	4-1250/9	15	160L
	5,5	132S		18,5	180M
	7,5	132M		22	180L
	9,2	132M		30	200M
	11	160M	4-1250/12	37	225S/M
	15	160L		15	160L
	18,5	180M		18,5	180M
4-1000/12	22	180L		22	180L
	5,5	132S		30	200M
	7,5	132M		37	225S/M
	9,2	132M			
	11	160M			
	15	160L			
	18,5	180M			
	22	180L			

LGAI Technological Center, S.A. N.I.F. A63207492

TECHNICAL ANNEX

0370-CPR-0923

HGHT RANGE 6 Poles					
Model	Power (kW)	Motor size	Model	Power (kW)	Motor size
6-800/3	0,55	80	6-1000/3	1,1	90L
	0,75	90S		1,5	100L
	1,1	90L		2,2	112M
	1,5	100L		3	132S
6-800/6	0,55	80	6-1000/6	4	132M
	0,75	90S		1,5	100L
	1,1	90L		2,2	112M
	1,5	100L		3	132S
	2,2	112M		4	132M
6-800/9	0,75	90S	6-1000/9	5,5	132M
	1,1	90L		7,5	160M
	1,5	100L		2,2	112M
	2,2	112M		3	132S
	3	132S		4	132M
6-800/12	0,75	90S	6-1000/12	5,5	132M
	1,1	90L		7,5	160M
	1,5	100L		2,2	112M
	2,2	112M		3	132S
	3	132S		4	132M
6-900/3	0,75	90S	6-1250/3	5,5	132M
	1,1	90L		7,5	160M
	1,5	100L		2,2	112M
	2,2	112M		3	132S
6-900/6	1,1	90L	6-1250/6	4	132M
	1,5	100L		5,5	132M
	2,2	112M		7,5	160M
	3	132S		9,2	160L
	4	132M		11	160L
6-900/9	1,1	90L	6-1250/9	15	180M
	1,5	100L		5,5	132M
	2,2	112M		7,5	160M
	3	132S		9,2	160L
	4	132M		11	160L
6-900/12	5,5	132M	6-1250/12	15	180M
	1,1	90L		18,5	200L
	1,5	100L		22	200L
	2,2	112M		5,5	132M
	3	132S		7,5	160M
	4	132M		9,2	160L
	5,5	132M		11	160L
				15	180M
				18,5	200L
				22	200L

* Note: The extractors have been tested at 300 °C / 2 hours